Applications of Neural Networks to Modeling and Control of Particle Accelerators

Auralee Edelen


Fermilab Accelerator Physics and Technology Seminar

8 June 2017


Overview


- Background on Neural Networks
- Control Challenges in Particle Accelerators
- Overview of Applications (with some examples)
 - Online Modeling
 - Model Predictive Control
 - Virtual Diagnostics
 - Failure Prediction, Anomaly Detection, and Machine Protection
 - Reinforcement Learning / Neural Network Control Policies
 - Incorporating Image-based Diagnostics into Control Policies
- Final Notes
 - Practical Challenges
 - Funding Climate
 - Conclusions

What are neural networks?




a neuron or node







a neuron or node

a feed-forward network











a neuron or node

a feed-forward network

a recurrent network



 $x = \begin{bmatrix} 0 & 0 & 0 \\ 0 & 0 & 0 \end{bmatrix}$





a neuron or node

a feed-forward network

a recurrent network

... many more architectures!






a neuron or node

a feed-forward network

... many more architectures!

See, for example, the Neural Network Zoo website.



How does this relate to "machine learning," "artificial intelligence," and "deep learning"?

...what do these terms mean anyway?

Field Taxonomy (as of now...)

- Artificial Intelligence (AI)
 - Concerned with enabling machines to exhibit aspects of human intelligence: knowledge, learning, planning, reasoning, perception
 - Narrow Al: focused on a task or similar set of tasks
 - General AI: human-equivalent or greater performance on any task
- Machine Learning (ML)
 - Enabling machines to complete tasks without being explicitly programmed
 - Common tasks: Regression, Classification, Clustering, Dimensionality Reduction
- Neural Networks (NNs)
 - An approach within ML that uses many connected processing units
 - Many different architectures and training techniques
- Deep Learning (DL)
 - Learning hierarchical representations
 - Right now, largely synonymous with deep (many-layered) NN approaches

Note that these definitions are not rigid: there is a lot of fluidity in the field

Artificial Intelligence

Machine Learning

Neural Networks

Deep Learning

e.g. Gaussian Process Optimization


e.g. Evolutionary Algorithms, Swarm Intelligence

e.g. Simplex, Gradient Descent

Mathematical Optimization

How do neural networks "learn"?

Basic Learning Paradigms



Supervised Learning

learn known input/output pairs






no labeled data → infer structure

Reinforcement Learning

interact with the environment \rightarrow adjust behavior based on reaction

Example: multiple-input, single-output process model

Data set of **input** and **output** pairings:



Want to find approximate map: g(x) = y

Model Learning Model Learning Optimization Input Process

Basic Update Example

$$C(w,b) = \frac{1}{2t_n} \left[\sum_{t_n} (y_{t_n} - \widetilde{y}_{t_n})^2 \right]$$

$$w_k \to w'_k = w_k - \alpha \frac{\partial C}{\partial w_k}$$

$$b_k \rightarrow b'_k = b_k - \alpha \frac{\partial C}{\partial b_k}$$

Basic Structures

$$x_{1} \longrightarrow w_{1}x_{1}$$


$$\vdots \longrightarrow f$$

$$x_{n} \longrightarrow w_{n}x_{n}$$


$$b$$

$$f\left(\sum w_{n}x_{n} + b\right) = a$$

e.g.
$$f(z) = \frac{2}{(1+e^{-2z})} - 1$$



How this all fits together for NNs



*arguably broader than just "machine learning"

An Architecture for Intelligent Control of Particle Accelerators

Optimization and control of a small-angle negative ion source

William B. Klein, Robert T. Westervelt

Vista Control Systems Inc., Los Alamoy ew Mexico 87544

OKAGY New Durit Lugar Of Mexico 87131

Volume 72, Issue 2, November 1992, Pages 271-289

Ing an on-line adaptive controller based on the John Source

Mead Ra, b, R.S. Bowlings sk & Brown Dave tried of Signal and Atoms

Volume 72, Issue 2, November 1992, Pages 271-289

OKAGY New Durit Lugar Of Accelerators

Volume 72, Issue 2, November 1992, Pages 271-289

Ing an on-line adaptive controller based on the John Source

Mead Ra, b, R.S. Bowlings sk & Brown Dave tried of USINS NEURAL

OKAGY New Durit Lugar Of Mexico 87131

Propositions of PACO9, Vancouver, BC, Canada

ELECTRON BEAM ENECTRON CONTROLLER AT THE AUGUST OF THE CONTROLLER AT THE AUGUST

A Beam Diagnostic System for Accelerator Using Neural Networks

Yuko Kijima, Katsuhisa Yoshida, Manabu Mizota Accelerator Projects, Nuclear Fusion Development Dept., Mitsubishi Electric Corporation

Accelerator Beamline Tuning

... so, what is different now?

Increased computational capability enables more complicated NN architectures and faster training + larger data sets





Accessibility of HPC clusters




Can **easily share** large data sets, code, and computing setups (e.g. via cloud computing services)

Up-and-coming advancements: neuromorphic hardware



New network architectures and training paradigms, such as long short term memory (LSTM) networks, neural turing machines, and generative adversarial networks (GANs)



Better theoretical understanding of NNs and improved optimization methods

Applications have driven a lot of advancement (both algorithmic and practical/heuristic)




Google

... so, what is different now?

New network architectures and

Increased comenables more coand faster training

Learning to Pivot with Adversarial Networks



Gilles Louppe
New York University
g.louppe@nyu.edu


Michael Kagan
SLAC National Accelerator Laboratory
makagan@slac.stanford.edu

Kyle Cranmer
New York University
kyle.cranmer@nyu.edu

er theoretical erstanding of

Shutterstock

Up-and-coming advancements: neuromorphic hardware



... so, what is different now?

Increased computational capability

enables more complicated NN architectures and faster training + larger data sets

> much greater overall technological maturity
> much greater overall technological maturity
> many advances in the last 3-5 years
> many advances in the last 3-5 years

New network architectures and training paradigms, such as long short term memory (LSTM) networks, neural turing machines, and genera

Up-and-coming advancements: neuromorphic hardware

GPUs



Applications have driven a lot of advancement (both algorithmic and practical/heuristic)



Let's talk about accelerators...



http://fast.fnal.gov/gallery.html

Interesting Technical Challenges


- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior


Strong Incentives for Better Control

- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role


Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:


- → of great interest for research in control and machine learning
- → lots of opportunity to both gain from and contribute to this area





Fermilab





Cooling Bill by 40%

Interesting Technical Challenges

- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior

Strong Incentives for Better Control

- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role

Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:

- of great interest for research in control and machine learning
- lots of opportunity to both gain from and contribute to this area



https://googleblog.blogspot.com

Interesting Technical Challenges

- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior

Strong Incentives for Better Control

- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role


Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:

- \rightarrow of great interest for research in control and machine learning
- → lots of opportunity to both gain from and contribute to this area

DeepMind Al Reduces Google Data Centre Cooling Bill by 40%

Transport delays, variable heat load

Efficient servers alone not enough



https://googleblog.blogspot.com

Interesting Technical Challenges

- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior


Strong Incentives for Better Control

- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role

DeepMind Al Reduces Google Data Centre

Cooling Bill by 40%

Transport delays, variable heat load Efficient servers alone not enough



A. L. Edelen, et al. IPAC 15, TUPO A 5 I



https://googleblog.blogspot.com

Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:

- \rightarrow of great interest for research in control and machine learning
- \rightarrow lots of opportunity to both gain from and contribute to this area

Interesting Technical Challenges


- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior

Strong Incentives for Better Control

- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role

DeepMind Al Reduces Google Data Centre Cooling Bill by 40%

Transport delays, variable heat load Efficient servers alone not enough



A. L. Edelen, et al. IPAC 15, TUPOA5 I

Using a neural network model!

https://googleblog.blogspot.com

Looks vaguely familiar...

Transport delays, variable heat load, complex dynamics

Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:

- \rightarrow of great interest for research in control and machine learning
- \rightarrow lots of opportunity to both gain from and contribute to this area

Interesting Technical Challenges

- Complex/nonlinear dynamics
- Many small, compounding errors
- Many parameters to monitor and control
- Interacting sub-systems
- On-demand changes in operational state
- Diagnostics sometimes limited or not put to full use in control (e.g. images)
- Time-varying/ non-stationary behavior

Strong Incentives for Better Control


- Cost of running → Time/energy efficiency of control
- Cost of unintended down-time → Personnel cost, user time, bulk scientific output
- Achieving performance needed for science goals and other applications
 - improving accelerator components and control both play a role

Uncertain, time-varying, nonlinear, many-parameter systems with continuous action spaces:


- → of great interest for research in control and machine learning
- \rightarrow lots of opportunity to both gain from and contribute to this area

DeepMind AI Reduces Google Data Centre Cooling Bill by 40%

Transport delays, variable heat load Efficient servers alone not enough



A. L. Edelen, et al. IPAC 15, TUPO A 5 I



https://googleblog.blogspot.com


Looks vaguely familiar...

Transport delays, variable heat load, complex dynamics



Cryo plant photo: A. Grassellino talk at IPAC '17, (THPPA2)

Example from LCLS



2015: 450 hand tuning hours, 250 dedicated!

⇒ Lots of opportunity to speed operations and relieve operator load

We rely heavily on operators for day-to-day control tasks ...



Fermilab Control Room Photo: Reidar Hahn, FNAL

... so what can we learn from them, and what analogous techniques can we use?

Inspiration from Operators



Application Areas for Accelerators

- Online modeling → NN model
- Time delays → model predictive control + NN models
- Image-based diagnostics → convolutional or locally-connected NNs
- Frequent switching between operating conditions

 NN policy
- Virtual diagnostics → NN model trained from intercepting diagnostics or simulation
- Encode an existing policy and/or adapt upon it → NN policy
- High-level assessment of machine or device states \rightarrow NN process model, classifier
- Failure prediction / Anomaly detection -> NN process model, classifier

Online Modeling

 Operators maintain a learned mental machine model: let's supplement it

• Ideally:

Fast-executing, but accurate enough to be useful

This can be very hard!

- · Use measured inputs directly from machine
- Combine a priori knowledge + learned parameters
- Applications
 - A tool for operators + virtual diagnostics
 - Predictive control
 - Help flag aberrant behavior

Yields a fast-executing model that can be used operationally, but approximates behavior from high-fidelity simulations (e.g. PIC codes, LPA)

One approach: faster modeling codes

- Simpler models (tradeoff with accuracy)
- Parallelization and GPU-acceleration of existing codes
 PARMILA X. Pang, PAC13, MOPMA13
 elegant I.V. Pogorelov, et al., IPAC15, MOPMA035
- Improvements in underlying modeling algorithms

(fractions of a second)

Another approach: machine learning model


- Once trained, neural networks can execute quickly
- Train on slow, high-fidelity simulation results
- Also train on measured results

An initial study involving this at FAST:

A. L. Edelen, et al. NAPAC I 6, TUPOA5 I


one PARMELA run: ~20 min

Model Predictive Control (Prediction + Planning)




Basic concept:

- I. Use a predictive model to assess the outcome of possible future actions
- 2. Choose the best series of actions
- 3. Execute the first action
- 4. Gather next time step of data
- 5. Repeat



Model Predictive Control (Prediction + Planning)



 N_m previous measurements

 N_p future time steps predicted

 N_c future time steps controlled

$$\sum_{i=1}^{N_p} \left\{ w_y \left[y_r(k+i) - y_p(k+i) \right] \right\}^2$$
(output variable targets)

$$\sum_{j=1}^{n_{cv}} \sum_{i=0}^{N_p-1} \left\{ w_{u,j} \left[u_j(k+i) - u_{j,ref}(k+i) \right] \right\}^2$$
(controllable variable targets)

$$\sum_{j=1}^{n_{cv}} \sum_{i=0}^{N_p-1} \left\{ w_{\Delta u,j} \left[u_j(k+i) - u_j(k+i-1) \right] \right\}^2$$
(movement size)

Temperature Control for the RF Photoinjector at FAST

Resonant frequency controlled via temperature


PID control is undesirable in this case:


- Long transport delays and thermal responses
- Recirculation leads to secondary impact of disturbances
- Two controllable variables: heater power + valve aperture

Applied model predictive control (MPC) with a neural network model trained on measured data: ~ 5x faster settling time + no large overshoot


LCW return LCW supply heater + control mixing chamber valve pump T02 long transport delay RF gun TIN TOUT **TCAV** Model Predictive Controller

Gun Water System Layout






Neural Network Model



Training data from machine



NN model

Why does this matter (for resonant frequency control in general)?

LLRF system will compensate for detuning by increasing forward power

But...

- Ability to do this bounded by the amplifier specs
- RF overhead adds to initial machine cost and footprint
- Using additional RF power → increasing operational cost
- Increased waste heat into cooling system → increasing operational cost
- If detuned beyond overhead \rightarrow interrupt normal operations (beam not properly accelerated or LLRF in frequency-tracking mode)

PIP-II Injector Test RFQ





Variable heating


Specification for GDR: 3-kHz maximum frequency shift Range of RF duty factors and pulse patterns (including up to CW)-

-16.7 kHz/°C in the vanes and 13.9 kHz/°C in the walls*


* A. R. Lambert et al., IPAC'15, WEPTY045








RFQ Detuning in CW Mode





Example of uncontrolled detuning in CW mode under a small change in cavity field (55 kV to 58 kV)

PI frequency control in CW operation under a small change in cavity field (55 kV to 58 kV)

What about a simple first-principles model, or a learned linear model?

10


measured input data → first-principles model


4 ms pulse duration, 10 Hz rep rate

variety of valve and power settings

1.67 kHz RMS error4.01 kHz max error

not good enough!







Time [h]


.5


2



Neural Network Model










Built a python-based control framework

- Executes on controls network linux computer
- PI control in regular operational use
- Preparing for test of MPC
- Designed to be portable + modular









Predict what diagnostics might look like when they are unavailable or don't exist


(fast a priori simulation, or fast ML model trained using simulation data) Real values Online Real-time prediction of beam dynamics at various locations Model from machine


e.g. GPU-accelerated PARMILA at LANSCE

- X. Pang, et al., PAC13, MOPMA13
- X. Pang, IPAC 15, WEXC2
- X. Pang and L. Rybarcyk, CPC185, is. 3 (2014)
- L. Rybarcyk, et al., IPAC 15, MOPWI033
- L. Rybarcyk, HB2016, WEPM4Y01










Machine learning applied to single-shot x-ray diagnostics in an XFEL

A. Sanchez-Gonzalez, P. Micaelli, C. Olivier, T. R. Barillot, M. Ilchen, A. A. Lutman, A. Marinelli, T. Maxwell, A. Achner, M. Agåker, N. Berrah, C. Bostedt, J. Buck, P. H. Bucksbaum, S. S. Carron Montero, ^{4, 10} B. Cooper, ¹ J. P. Cryan, ² M. Dong, ⁵ R. Feifel, ¹¹ L. J. Frasinski, ¹ H. Fukuzawa, ¹² A. Galler, G. Hartmann, A. N. Hartmann, W. Helml, A. S. Johnson, A. Knie, A. O. Lindahl, J. II. J. Liu, K. Motomura, M. Mucke, C. O'Grady, J-E. Rubensson, E. R. Simpson, R. J. Squibb, C. Såthe, ¹⁵ K. Ueda, ¹² M. Vacher, ^{16,17} D. J. Walke, ¹ V. Zhaunerchyk, ¹¹ R. N. Coffee, ⁴ and J. P. Marangos ¹

Used archived data to learn correlation between fast and slow diagnostics

Looked at a variety of ML methods and different diagnostics



A. Sanchez-Gonzalez, et al. https://arxiv.org/pdf/1610.03378.pdf

Random

Fast simple




FIG. 4. Spectral shape prediction for a single pulse. (a) Histogram of agreements between the predicted and the measured spectra for the test set using the 4 different models. (b-e) Examples of the measured and the predicted spectra using a neural network to illustrate the accuracy for different agreement values.

Fault Prediction (Prognostics) + Anomaly Detection

Operations:

- Identify aberrant behavior that is correlated with faults, failures, or poor machine states
- Detect deviations from normal operating conditions that may otherwise go noticed

Machine Protection:

catastrophic failures and faults sometimes preceded by tell-tale signs

Replacement Cycles:

predict time-to-failure based on real-time and archived data

Using LSTM recurrent neural networks for detecting anomalous behavior of LHC superconducting magnets

Maciej Wielgosz^a, Andrzej Skoczeń^b, Matej Mertik^c


^aFaculty of Computer Science, Electronics and Telecommunications, AGH University of Science and Technology, Kraków, Poland ^bFaculty of Physics and Applied Computer Science, AGH University of Science and Technology, Kraków, Poland ^cThe European Organization for Nuclear Research - CERN, CH-1211 Geneva 23 Switzerland "Some of the most dangerous malfunctions of the magnets are quenches which occur when a part of the superconducting cable becomes normally-conducting."

Aim: use a recurrent NN to identify quench precursors in voltage time series.


> Predict future behavior, then classify it


Initial study with small data set:

- 425 quenches for 600 A magnets
- Used archived data from 2008 to 2016
- 16-32 previous values → predict a few time steps ahead



Neural Network Policies and Reinforcement Learning





Can train on models first to get a good initial solution before deployment


Actor Optimization Teacher

Can use supervised learning to first approximate the behavior of a different control policy

Actor-Critic Methods

- Critic maps states or state/action pairs to an estimate of long-term reward
- Could be a NN, tabular, etc.
- Critic provides training signal to actor


Without actor: use an optimization algorithm with the critic





Computer Vision + Neural Network-based RL

• Image diagnostics -> would be nice to use directly, and some yield relatively complicated information

e.g. XTCAV at SLAC








C. Behrens, et al., Nat. Commun. **5**, 3762 (2014)

- D. Ratner, et al., PRSTAB18, 030704 (2015)
- Convolutional Neural Networks (CNNs) → very good at image processing
- Reinforcement Learning (RL) → can learn control policies from data

Why not try using image based diagnostics directly in learned control policies? What's a relatively simple test case to start with?

Initial Study at FAST/IOTA



Photocathode RF Gun

Superconducting Capture Cavities

Initial Study: Choose Gun Parameters Based on Laser Spot

Motivation:

- Gun phase and solenoid strength tuned daily
- Asymmetries in initial laser distribution result in emittance asymmetries downstream
- Would be nice to obtain optimal gun phase and solenoid strength for a given initial laser distribution automatically (and perhaps prioritize x or y emittance to minimize)



Example virtual cathode image (10 Aug. 2016)

Other perks:


- PARMELA simulation based on survey data already in existence (J. Edelen)
- Try out creating a fast NN modeling tool from slower-executing simulations

Initial Study: Choose Gun Parameters Based on Laser Sp.


Motivation: Why not just use online optimization? Gun phase and so Why not just fit a Gaussian to the laser spot to get the information The point of this study: explore this approach on a simple d X Othe PAR aiready in existence (J. Edelen) • Try nodeling tool from slower-executing simulations


Initial Study: Steps

- Gather simulation data from PARMELA scans
- Create a NN model
 - Be certain that the necessary information can be extracted from the image, gun phase, and solenoid strength
- Train a RL controller using that model
- Extension beyond simulation (tentative):
 - Incorporate measured data into model and update controller
 - Carefully test on machine




model inputs and outputs






CNN Model: Simulation Data

- PARMELA simulations from the gun up to the exit of CC2
 - 2-D space charge routine
 - Scanned gun phase, solenoid strength, initial beam distribution
- Two sets of data:
 - Fine scans (steps of 5° phase, 5% sol. str.) for sims just past the gun
 - Coarse scans (steps of 10° phase, 10% sol. str.) for sims up through
 CC2
- Simulated "virtual cathode images"
 - Going from VCI → initial beam distribution ok from prior work
 - Initial beam distribution → simulated VCI probably ok
 - Obviously very "well-behaved" examples






Simulation predictions after CC2. Dashed lines are xemittance, solid lines are y-emittance.


Caveat: doesn't take into account coupling...later changed NN setup to predict sigma matrix, and also used a 3D space charge routine.

CNN Model: Two Representative Plots

Dashed lines are NN predictions and solid lines are simulation results



Top-hat initial beam, 0° RF phase, after gun



Asymmetric Gaussian initial beam, 0° RF phase, after CC2

For the gun data, all MAEs are between 0.4% and 1.8% of the parameter ranges. For the CC2 data, all MAEs are between 0.9% and 3.1% of the parameter ranges.

→ Not bad for such a small training set

Fast Switching Between Trajectories


- 76 BPMs, 57 dipoles, 53 quadrupoles
- Traditional approach has never worked (linear response matrix)
- Rely on one expert for steering tune-up
- Want to specify small offsets in trajectory at some locations
- Didn't initially have an up-to-date machine model available

Learn responses (NN model) from tune-up data and dedicated study time:

dipole + quadrupole settings → predict BPMs

Train controller (NN policy) offline using NN model: desired trajectory → dipole settings (and penalize losses + large magnet settings)

Test on machine: check to make sure model prediction still accurate and try static controller (non-adaptive)



Fast Switching Between Trajectories

- 76 BPMs, 57 dipoles, 53 quadrupoles
- Traditional approach has never worked (linear response matrix)
- Rely on one expert for steering tune-up
- Want to specify small offsets in trajectory at some locations
- Didn't initially have an up-to-date machine model available

Learn responses (NN model) from tune-up data and dedicated study time:

dipole + quadrupole settings → predict BPMs

Train controller (NN policy) offline using NN model: desired trajectory → dipole settings (and penalize losses + large magnet settings)


Test on machine: check to make sure model prediction still accurate and try static controller (non-adaptive)

(Very) Preliminary Results:

Model Errors for BPMs:

Training Set: 0.07 mm MAE 0.09 mm STD Validation Set: 0.08 mm MAE 0.07 mm STD Test Set: 0.08 mm MAE 0.03 mm STD

Controller: random initial states → on average within 0.2 mm of center immediately



Fast Switching Between Trajectories

- 76 BPMs, 57 dipoles, 53 quadrupoles
- Traditional approach has never worked (linear response matrix)
- Rely on one expert for steering tune-up
- Controller: random initial states -> on average * Wan Similar Kind of Task: switching between FEL frequencies (in progress)
- Didn \rightarrow simulation study with CSU FEL (3 6 MeV e- beam \rightarrow space charge)
 - → use optimization iteration output from simulation to train NN model
 - > train controller via interaction with NN model, then with simulation
 - → given target wavelength: set quads, gun phase, solenoid strength, RF power

Train controller (NN policy) offline using NN model: desired trajectory → dipole settings (and penalize losses + large magnet settings)

Test on machine: check to make sure model prediction still accurate and try static controller (non-adaptive)

(Very) Preliminary Results:

Model Errors for BPMs:

Training Set: 0.07 mm MAE 0.09 mm STD Validation Set: 0.08 mm MAE 0.07 mm STD

0.08 mm MAE Test Set: 0.03 mm STD

200 400 600 800 Sample Number (Scanning over Magnet Settings)

Need a sufficient* amount of reliable* data

(but not as much as is sometimes claimed in DL)

Training on Measured Data

Undocumented manual changes (e.g. rotating a BPM)

Relevant-but-unlogged parameters

Availability of diagnostics

Observed parameter range in archived data

Time on machine for characterization studies (schedule + expense)

Ideal case:

- comprehensive, high-resolution data archive
- excellent log of manual changes

Training on Simulation Data

How representative of the real machine behavior?

Input/output parameters need to translate directly to what's on the machine (quantitatively)

High-fidelity (e.g. PIC)

→ time-consuming to run

Retention + availability of prior results: (optimize and throw the iterations away!)

Deployment

Initial training is on HPC systems → deployment is typically not*

- Execution on front-end: necessary speed + memory?
- Subsequent training: on front-end or transfer to HPC?


Software compatibility for older systems: interface with machine + make use of modern ML software libraries

I/O for large amounts of data

Final Notes: Funding Climate

Advanced Scientific Computing Research

DOE supercomputers.



American Institute of Physics | aip.org/fyi

Final Notes

- Neural networks are very flexible tools \rightarrow far more powerful in recent years
- Mostly preliminary results so far, but making progress (+ more infrastructure in place)
- Lots of opportunities to use neural networks (and ML more broadly) to improve accelerator performance on both existing and future machines

Fermilab has a strong presence in machine learning (especially for neural networks/HEP)

Lots of potential for fruitful collaborations on the accelerator side

→ LBNL, SLAC, LANL, CERN all interested in applying ML to accelerator modeling/controls

Some possible experiments at Fermilab:


- Ion sources (MPC/RL)
- Cryogenic system control (MPC/RL)
- Fermi Test Beam Facility (fast switching)
- Muon Campus (virtual diagnostics, online modeling)
- Phase space manipulations at FAST (fast switching)

Thanks for your attention!

Final Notes: Fermilab has a strong presence in machine learning (especially for DL/HEP)


- See Fernanda Psihas New Perspectives 2017 talk
- Ramping up HPC resources
- Slack channel: https://hepmachinelearning.slack.com
- Journal Club meetings
- Monthly Intro meetings
- Website: http://machinelearning.fnal.gov/

CNN Applications for HEP June 9th 10:30 AM, One West




CNN Model: Simulation Data

- PARMELA simulations from the gun up to the exit of CC2
 - 2-D space charge routine
 - Scanned gun phase, solenoid strength, initial beam distribution
- Two sets of data:
 - Fine scans (steps of 5° phase, 5% sol. str.) for sims just past the gun
 - Coarse scans (steps of 10° phase, 10% sol. str.) for sims up through
 CC2
- Simulated "virtual cathode images"
 - Going from VCI → initial beam distribution ok from prior work
 - Initial beam distribution → simulated VCI probably ok
 - Obviously very "well-behaved" examples



Parameter Ranges used for Model Training

Parameter	Gun Data		CC2 Data	
	Max Value	Min Value	Max Value	Min Value
N_p	5001	1015	5001	1004
ε _{nx} [m-rad]	2.50E-04	1.60E-06	4.00E-04	9.10E-07
ε _{ny} [m-rad]	2.40E-04	1.60E-06	4.00E-04	8.50E-07
α_x [rad]	14.1	-775.1	0.8	-149.8
α_y [rad]	14.5	-797	0.7	-154.5
β_x [m/rad]	950.4	7.90E-02	820.2	0.7
β_y [m/rad]	896.8	8.40E-02	845.7	0.81
E [MeV]	4.6	3.2	47.2	42.8



Simulation predictions after CC2. Dashed lines are x-emittance, solid lines are y-emittance.
Caveat: doesn't take into account coupling...later changed NN setup to predict sigma matrix, and also used a 3D space charge routine.

For normalized sol strength, 1 is the setting that produces a peak axial field of $1.8 \, \mathrm{kG}_{\mathrm{ay}}$ 2017

CNN Model: Performance

Parameter	Train. MAE	Train. STD	Val. MAE	Val. STD
N_p	69.5	79.8	70.7	75.7
ϵ_{nx}	2.30E-06	3.50E-06	2.40E-06	3.20E-06
ϵ_{ny}	2.30E-06	3.40E-06	2.40E-06	3.20E-06
α_{x}	9	14.9	10.9	16
α_{y}	8.8	15.3	10.8	16.1
β_{x}	12.1	17.6	14.8	18.9
β_{y}	11.7	16.7	14.3	17.9
Е	4.90E-03	4.90E-03	5.50E-03	6.00E-03

Parameter	Train. MAE	Train. STD	Val. MAE	Val. STD
N_p	103.7	141.2	123.3	176.8
ϵ_{nx}	1.00E-05	1.20E-05	1.20E-05	1.60E-05
ϵ_{ny}	1.00E-05	1.30E-05	1.20E-05	1.50E-05
α_{x}	3.4	6.6	3.1	5.9
α_{v}	3.4	6.6	3.1	5.9
β_x	16.3	33.5	14.7	27.8
β_{ν}	16.4	33.6	14.8	27.5
Е	4.00E-02	3.90E-02	4.60E-02	6.20E-02

Performance for the predictions after the gun

Performance for the predictions after CC2

For the gun data, all MAEs are between 0.4% and 1.8% of the parameter ranges. For the CC2 data, all MAEs are between 0.9% and 3.1% of the parameter ranges.

→ Not bad for such a small training set

Present Status and Next Steps

Improving the quality of the setup:

- Predicting the full sigma matrix
- More realistic initial distributions
- Using 3D space charge routine
- Using locally-connected layers
- Switching to ASTRA
 (greater execution speed → more training data)

Next steps (in tandem):

- Finish simulation study with present setup
- Extend to phase space manipulation simulation study
- Solidify plans for incorporating measured data and testing controller
 - Need to align available inputs/controllable variables (e.g. sigma matrix vs. info from emittance monitors, rotation of quads, etc.)
 - Also depends on run schedule, status of new emittance monitors, solid time with consistent setup, etc.


Expanding scope to phase space manipulations:


- Specify a target sigma matrix
- Include quads after CC2, capture cavity phases, etc.
- Collaborating with NIU:
 - RTFB transform is a possible application
 - Alex Halavanau running simulation scans with NIU's newer model


 more training data

Also, if you have some other possible application and have or can easily obtain training data: don't hesitate to get in touch!

MPC Benchmark Controller: Actions







Backpropagation

Vectorized notation: $a_j = f(\sum_k w_{jk} x_k + b_j) \rightarrow f(wx + b)$

Layer-by layer: $a^l = f(w^l a^{l-1} + b^l) = f(z^l)$

 a_j j^{th} node activation

f applied element-wise

 b_i j^{th} node bias

 $\delta_j^l \equiv \frac{\partial C}{\partial z_i^l}$

 W_{jk} j^{th} node in layer l, k^{th} node in l-1

$$\delta_j^{N_l} = \frac{\partial C}{\partial a_j^{N_l}} f'(z_j^{N_l}) \qquad \to \quad \delta^{N_l} = \nabla_a C \odot f'(z^{N_l})$$

$$\delta_j^l = \sum_k \frac{\partial C}{\partial z_k^{l+1}} \frac{\partial z_k^{l+1}}{\partial z_j^l} \qquad = \sum_k \delta_k^{l+1} \frac{\partial z_k^{l+1}}{\partial z_j^l}$$

$$=\textstyle\sum_k w_{kj}^{l+1} \delta_k^{l+1} f'(z_j^l)$$

$$z_k^{l+1} = \sum_j w_{kj}^{l+1} a_j^l + b_k^{l+1}$$
$$= \sum_j w_{kj}^{l+1} f(z_j^l) + b_k^{l+1}$$

$$\frac{\partial z_k^{l+1}}{\partial z_i^l} = w_{kj}^{l+1} f'(z_j^l)$$

For each training instance:

I. Forward Pass:

For
$$l = 1, 2, 3 ... N_l$$

$$z^l = w^l a^{l-1} + b$$

$$a^l = f(z^l)$$

2. 'Error':

$$\delta^{N_l} = \nabla_a C \odot f'(z^{N_l})$$

3. Backward Pass:


For
$$l = N_l - I, N_l - 2, ... I$$


$$\delta^l = w^{l+1} \delta^{l+1} \odot f'(z^l)$$

4. Final Derivatives:

$$\frac{\partial C}{\partial w_{jk}^l} = a_k^{l-1} \delta_j^l \qquad \frac{\partial C}{\partial b_j^l} = \delta_j^l$$

FAST Gun Temperature Considerations







$$P_{cool} = \frac{(T_{OUT}[^{\circ}\text{C}] - T_{IN}[^{\circ}\text{C}]) \times (Flow [GPM])}{Water Cooling Capacity \left[\frac{GPM - ^{\circ}\text{C}}{kW}\right]}$$


$$P_{cool} = P_{IN} \approx P_{RF_{avg.}}$$

In the resonance control framework

- N_p future time steps
- *m* previous measurements for each input variable
- "actions" are vane and wall flow valve settings










PXIE RFQ

3-kHz max. freq. shift

0.1-°C water stabilization







FAST Photoinjector

RF electron gun at the Fermilab Accelerator Science and Technology (FAST) facility

- Long, variable time delays
- Tight tolerances
- Recursive behavior
- Two controllable parameters

FACT DE C	D	
FAST RF Gun Parameters		
Gun Parameters		
Туре	Photoinjector	
Number of cells	1½	
RF Mode	$ ext{TM}_{010,\pi}$	
Loaded Q	~11,700	
RF Frequency	1.3 GHz	
Frequency Shift	23 kHz/°C	
Nominal Operating Parameters		
Macropulse Duration	1 ms	
Repetition Rate	1-5 Hz	
Bunch Frequency	3 MHz	
Design Gradient	40-45 MV/m	
Power Source	5 MW Klystron	




Photo: P. Stabile



PIP-II RFQ

Right now: 100s to 5ms pulse at 10 Hz ~100 kW forward RF power

PXIE RFQ Parameters		
RFQ Design Parameters		
RF frequency	162.5 MHz	
Q-factor	~13,900	
Loaded Q	~7,000	
Physical Length	4.45 m (2.4 wavelengths)	
Vane-to-Vane Voltage	60 kV	
Estimated Power Dissipation	< 100 kW	
RF Repetition Rate	pulsed – CW	
Beam Parameters		
Current	0.5 – 10 mA (nominal 5 mA)	
Input Energy	30 keV	
Output Energy	2.1 MeV	




Constructed by LBNL



High-intensity RFQ for the PIP-II Injector Experiment (PXIE)

- —Time delays
- Large, dynamic frequency response
- Tight tolerances
- Coupling
- Recursive behavior
- —Three controllable parameters



PI frequency control during pulsed RF operation for a 2-ms increase in pulse duration and a cavity field of 65 kV